

From: [Patrick Trowbridge](#)
To: [Brent Bybee](#); [Mel Mills](#); [Geoff Wullschlager](#); [Rachel Vickers](#)
Subject: Photos of flag lots with septic tanks
Date: Thursday, September 26, 2024 4:17:29 PM
Attachments: [IMG_9849.jpg](#)
[IMG_9850.jpg](#)



Brent, I'd like to have these photos included in the public comments regarding the city engineers comments that a septic tank will not fit inside of a 20' flag . Here are two examples of septic tanks fitting inside of existing 20' flagpoles. A driveway only needs to 10' wide. Essentially if we are going to widen the plot to 30' we might as well keep the lots the way they are and use the 15'x 5' foot for the tank. The problem however is the added cost of an ejector pump that will be needed to push the affluent from the home out to the tank at the tanks being placed at the house make the most sense for cost effectiveness.

Sent from Gmail Mobile



